

EN-21: Module communications settings

- When the 'New HVAC station wizard' creates a station, one of the many things it does is to install and pre-configure a Modbus communications network into the station so that when the station starts with its connected Vykon HVAC I/O modules, they immediately communicate. This speeds up the process of installation and commissioning. This engineering note details for reference, some of the property settings of the Vykon HVAC Modbus driver.

